



EC - Declaration of Conformity

Manufacturer: Pipelife Slovenija d.o.o.
Ljubljanska 52/a, 1236- Trzin
Slovenia
Tel.: +386 1 530 2220 Fax: +386 1 530 2222
E-mail: info@pipelife.si Web: www.pipelife.si

Production site: Pipelife Slovenija d.o.o.
Ljubljanska 52/a, 1236- Trzin
Slovenia
Tel.: +386 1 530 2220 Fax: +386 1 530 2222
E-mail: info@pipelife.si Web: www.pipelife.si

Declares that the products: Septic tanks CLEANBOX SBR are in conformity with the Construction Products Directive (CPD 89/106/EEC) meeting the requirements given in Annex ZA of EN 12566-3 "Small wastewater treatment systems for up to 50 PT – Part 3: Package and/or site assembled domestic wastewater treatment plants".

Provisions to which the Septic tanks conforms:

Characteristic	Performance declaration	ITT report	Approved body
Treatment efficiency (effectiveness of treatment)	COD 87 % BOD 96 % TSS 91 %	Report No. PIA2006-006a	PIA Aachen Germany
Nominal designation (treatment capacity)	0,6 Cubic meters / day	Report No. PIA2006-006a	PIA Aachen Germany
Watertightness	Pass	Report N. 246953-2	DTI Copenhagen Denmark
Crushing resistance and maximum load deformation	Pass	Report N. 1306987	DTI Copenhagen Denmark
Durability	Pass	Report N. 1306987	DTI Copenhagen Denmark

This declaration of conformity is valid for the products produced after 15 05 2009



Aleš Fugina
General Manager Pipelife Slovenija.

Trzin, 15 05 2009



Small wastewater treatment systems up to 50 PT: prefabricated plants

CE marking information given on the accompany documents

	
 Pipelife Slovenija d.o.o. Ljubljanska 52/a 1236- Trzin Slovenia www.pipelife.si 09	
EN 12566-3	
CLEANBOX SBR 3M3	
Hydraulic daily load:	0.6 m³/day
Material:	PE
Watertightness (water test):	pass
Crushing resistance:	pass
Treatment efficiency:	COD: 87% BOD: 96% TSS: 91%
pH	7,2
N_{tot}:	35%
Total phosphorus:	85%
Dissolved oxygen concentration:	NPD
Sludge production:	NPD
Electrical consumption:	0.8 kWh/d



Small wastewater treatment systems up to 50 PT: prefabricated plants

CE marking information to affix on the septic tank

